

Paper SD01

“Powerful” SAS® Techniques from the Windows API

Samuel T. Croker

ABSTRACT

Ever wonder how well that old laptop battery is performing? Is it possible to do online tests of a laptop battery to determine the best power configuration? Need a way to cleanly exit a SAS® process when the laptop battery is low or the system switches to auxiliary power? The Microsoft Windows API provides a method for polling system power sources and SAS makes designing a simple power source querying system easy. Keywords: Base SAS, MODULEN, SASCBTBL, Microsoft Windows XP/2000, Microsoft Windows API, GetSystemPowerStatus, SAS/GRAPH.

INTRODUCTION

The Windows API is a very useful group of methods and properties that are available to developers on a Windows platform. This type of API is also available to many other platforms but will not be covered by this document. There have been several very good papers written on how to use the Windows API so this example will only cover the barest of details as to using the Windows API. This application resulted from the desire to evaluate a laptop battery, and being disappointed by the cost of such applications. So the thought arose, “Why not use SAS?” Luckily, many of the details of using the Windows API within SAS has been researched in reported in several SUGI papers.

WINDOWS API AND SAS BASICS

The functions within the Windows API must first be prototyped before they are available to SAS. This prototype is stored in a file reference that has to be called `SASCBTBL`. This fileref is known to SAS and is used implicitly by the `MODULEN` or other `CALL MODULEx` routines.

For this example, the Windows API function *GetSystemPowerStatus* is used to get information about the current power configuration. For the *GetSystemPowerStatus* function, it was necessary to experiment a little with the informats in order to get meaningful data. The `IB4.` informat is the only informat that correctly loads the integer data of `BatteryLifetime` and `BatteryFullLifetime`. The boolean values are only correctly loaded using `IB1..`

```
filename SASCBTBL CATALOG 'sasuser.example.winbatt.source';
data _null_;
  file SASCBTBL;
  input;
  put _infile_;
cards4;
ROUTINE GetSystemPowerStatus
  minarg=6
  maxarg=6
  stackpop=called
  module=kernel32
  returns=long;
* LPSYSTEM_POWER_STATUS lpSystemPowerStatus ;
arg 1 num output fdstart format=ib1.;
arg 2 num output format=ib1.;
arg 3 num output format=ib1.;
arg 4 num output format=ib1.;
arg 5 num output format=ib4.;
arg 6 num output format=ib4.;
;;;
run;
```

The `SASCBTBL` file begins after the `CARDS4` statement. Everything following the `ROUTINE` statement is very

important for successful calling of the Windows API function. The line

```
* LPSYSTEM_POWER_STATUS lpSystemPowerStatus ;
```

is not a comment and is very important because it specifies the data structure that is returned by the GetSystemPowerStatus function.

Executing this data step will build a SOURCE entry in the work.example.winbatt.source catalog entry. A Source Catalog Entry is the same thing as a text file except that it is stored as a binary coallation within a SAS Catalog. This FILEREF could just as easily be a text file.

CALLING THE API FUNCTION

The following macro is a building block for a more complex example.

```
%macro scanbatterysingle;
  options nonotes nosource;
  data _null_;
    ACStatus=.;
    BatteryFlag=.;
    BatteryLifePercent=.;
    Reserved=.;
    BatteryLifeTime=.;
    BatteryFullLifeTime=.;
    put @1 'SEQ'
        @5 'Date/Time'
        @30 'AC'
        @35 'Flag'
        @41 '%' @45 'LF' @55 'LF_F';
    rc= modulen (
        "se"
        , 'GetSystemPowerStatus'
        , ACStatus
        , batteryflag
        , batterylifepercent
        , reserved
        , batterylifetime
        , batteryfulllifetime
        );
    sequenceno+1;
    date_time=datetime();
    put @1 sequenceno
        @5 date_time datetime19.
        @30 acstatus
        @35 batteryflag
        @41 batterylifepercent
        @45 Batterylifetime
        @55 batteryfulllifetime;
    format date_time datetime28.;
  run;
  options notes source;
%mend;
```

The results of calling this macro while the battery is being used (not AC power) is:

SEQ	Date/Time	AC	Flag	%	LF	LF_F
1	15SEP2005:21:06:41	0	0	35	3998	-1

The core of the Windows API access of this data step is the MODULEN function. The call routine CALL MODULEN can also be used for this type of access to the Windows API. The use of the MODULE function or call routine implicitly accesses the SASCBTBL file reference, so it has to exist for the function call to work. From this point forward, only the MODULEN function is discussed. The RC variable contains the return code for the module function and can be used to check for error conditions. This error checking is omitted in the example above but is shown in Appendix A.

So for each observation in the resulting data set (or null dataset as above) it is necessary to first define the data set variables that will contain the data that is returned by the MODULEN function. In the example, this is done by setting each of the variables to null values. Remember what the file that the SASCBTBL fileref references looks like. There are six values that the SASCBTBL specifies that will be returned. By defining these variables in the data step, then using them in the MODULEN function, the variables are associated with what is returned by the GetSystemPowerStatus Windows API function. In other words, MODULEN accesses the Windows API and links the parameters, or data step variables, in its call to the arguments in the ROUTINE statement. If the MODULEN call is successful, then the data step variables will contain the values that were returned by the Windows API call. The data step variables can be named anything since the ROUTINE statement and the Windows API function do not require names. The formats of the routine statement and the data step variables must be of the correct length for the data to make sense.

BUILDING A BATTERY PROFILE

The following macro takes the first example a little farther by adding iterative functionality to poll the battery at an interval, then store the data so that it can be compared to other experiments. This is done using five macro parameters:

group Suffix for each variable to differentiate between datasets on merge

cutoff Lowest percent for polling to accomodate power shutdowns

sampleint Time in seconds to wait between pollings

dsname Name of dataset for the group

appendto Name of dataset to append results to

```
%macro scanbattery(
    group          = 0          /* zero means create a new ds, > appends */
    ,cutoff        = 10         /* lowest percent to monitor */
    ,sampleint     = 5          /* sampling interval in seconds */
    ,dsname        = BatteryLife /* unit dataset name */
    ,appendto      = none       /* dataset to append new results to */
);
/* restrict log information */
options nonotes nosource;
data &dsname;
    length sequenceno 8;
    group=&group;
    /* set up parameters from the
       lpSystemPowerStatus data structure in the api */
    ACStatus_&group=.;
    BatteryFlag_&group=.;
    BatteryLifePercent_&group=.;
    Reserved_&group=.;
    BatteryLifeTime_&group=.;
    BatteryFullLifeTime_&group=.;
    /* column header */
    put @1 'SEQ'
        @5 'Date/Time'
```

```

@30 'AC'
@35 'Flag' @41 '%' @45 'LF' @55 'LF_F';
/* sample until the battery life
percent falls below the cutoff threshold */
do until (batterylifepercent_&group < &cutoff);
  /* access the api */
  rc= modulen ("*e"
    ,'GetSystemPowerStatus'
    ,ACStatus_&group
    ,batteryflag_&group
    ,batterylifepercent_&group
    ,reserved_&group
    ,batterylifetime_&group
    ,batteryfulllifetime_&group);
  if rc=0 then do;
    put "ERROR: GetSystemPowerStatus returned a fail code.";
    stop;
  end;
  /* nondimensional increment number to simplify graphing */
  sequenceno+1;
  /* add a datetime value for interest */
  date_time_&group=datetime();
  /* write out the last observation to the log for interest */
  put @1 sequenceno
    @5 date_time_&group datetime19.
    @30 acstatus_&group
    @35 batteryflag_&group
    @41 batterylifepercent_&group
    @45 Batterylifetime_&group
    @55 batteryfulllifetime_&group;
  /* save the last observation */
  output;
  /* wait before continuing.
The 1 stands for seconds and the
sampleint is the number of seconds to wait */
  call sleep(&sampleint,1);
end;
format date_time datetime28.;
run;
%if &appendto~="none" %then %do;
  data &appendto;
    merge &appendto &dsname;
    by sequenceno;
  run;
%end;
options notes source;
%mend ScanBattery;

```

/* Usage: In the following example an initial permanent result set is created (BatteryTest1) first. The subsequent statements append the result set to this BatteryTest1 dataset, differentiating the runs with the group variable. Do it this way because the plotbatteryresults macro will then make columns out of the percents for the groups so that they can be easily plotted against each other. This is useful for evaluating and displaying the power drop curves for multiple power profile configurations.*/

```
%scanbattery(group=0,dsname=BatteryTest1,cutoff=10,sampleint=5);
```

DISPLAYING THE RESULTS

The only difficulty in displaying associated graphs is knowing how to line up the starting points. Here the graphs are started at the beginning of each run.




Figure 1: Three Battery Profiles

The line with the steepest slope corresponds to a run when the laptop was being subjected to a processor intensive process. This caused the fan to run almost the entire time and the battery was depleted quickly. The second steepest slope corresponds to a run when all Microsoft Office applications were open, but not used. The least steep slope corresponds to a run where the laptop was in its initial startup configuration with nothing but startup processes open.

EXITING SAS PROCESSES AT POWER THRESHOLD

The hibernate or standby feature of most laptops is not always the best method for ending a long running process in SAS. If this is a problem or if the system is operating on a UPS with limited off-AC runtime it is nice to be able to cleanly exit the SAS process before the system goes into hibernate or standby mode. This could easily be accomplished by periodically polling the battery status within a SAS program, and providing code to cleanly exit when the remaining percent falls below a pre-defined level. For example, polling ended for the profile graphs generated above automatically when the battery percent remaining fell below 12%.

CONCLUSION

Connecting SAS to the Windows API can be useful in many ways. The GetSystemPowerSource function allows SAS to query the battery a laptop or UPS system. This functionality can be used to build power drain curves for various power configurations, or to control SAS processes when the power level falls below a certain threshold.

REFERENCES

Required	SAS® with the Windows API	David H. Johnson
	http://www2.sas.com/proceedings/sugi30/248-30.pdf	
Recommended	SASCBTBL Routine Statements	Richard A. DeVenezia
	http://www.devenezia.com/downloads/sas/sascbtbl/	
	GetSystemPowerStatus on MSDN	Microsoft Corporation
	http://msdn.microsoft.com/library/default.asp?url=/library/en-us/power/base/getsystempowerstatus.asp	

ACKNOWLEDGMENTS

Techniques from David Johnson and Richard DeVenezia’s papers on using the Windows API within SAS make up the bulk of this paper

CONTACT INFORMATION

Your comments and questions are valued and encouraged.

Contact the author(s): Name Samuel T. Croker
 City, State, ZIP Lexington, SC 29073
 E-mail: scoyote@scoyote.net

SAS and all other SAS Institute Inc. product or service names are registered trademarks or trademarks of SAS Institute Inc. in the USA and other countries. ® indicates USA registration. Other brand and product names are trademarks of their respective companies.